

Glass and Glazing Federation

Certifies that

Bekaert Specialty Films (UK) Ltd

Certificate No: **TC 0041**

10 MIL CLEAR Safety Film has passed Class 1B
of BS EN 12600 'Glass in Building – Pendulum
Test – Impact Test Method and Classification
for Flat Glass' on 6mm Float Glass

Tested at Wintech Engineering Ltd, UKAS accredited Test Laboratory, No.2223


Issued: *25 July 2001*

Chief Executive:



N Rees

Testing Officer:



S H Rice



Glass and Glazing Federation

Glass and Glazing Federation
44 – 48 Borough High Street
London
SE1 1XB
Tel: 020 7207 5872
Fax: 020 7357 7458

Test Facility:
WINTech Engineering Ltd
Halesfield 2
Telford TF7 4QH
Tel: 01952 586580
Fax: 01952 586585